

Town Hall
P.O. Box 548
27 Main Street
Salisbury, Connecticut 06068



TOWN OF SALISBURY
CONNECTICUT

CHARLES CARLETON
FIRE MARSHAL
Cell: 860-671-0277
Fax: 860-435-5172
Email: ccarleton@salisburyct.us

03/05/2021

Elizabeth Slotnick Architect
16 Prospect Street
Lakeville, CT 06039
860 435-1403 / eslotnick@snet.net
eslotnickarchitect.com

Dear Abeth,

Per your request, I have reviewed the Holley Place plans you forwarded to me. I do not find any problems with the plans provided that the building will have an automatic fire detection system and an automatic sprinkler system throughout. This would include the garage area underneath the building. Water authority approval is required for the sprinkler system.

Travel distances within the building to exits appear to be compliant. My only concern is Fire Department access on the west and south sides of the building. These areas will need to be kept clear of any obstructions that could interfere with Fire Department access. Fire lanes would need to be established, posted and enforced.

If you have any questions, do not hesitate to call.

Sincerely,


Charles Carleton

Fire Marshal, Town of Salisbury
860.671.0277 C
860.435.5196 O

RECEIVED

MAR 08 2021

LAND USE OFFICE
Salisbury, CT

cc: Abby Conroy
aconroy@salisburyct.us