

STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH

Manisha Juthani, MD
Commissioner



Ned Lamont
Governor
Susan Bysiewicz
Lt. Governor

Drinking Water Section

May 28, 2025

Mr. Robert Rubbo
Director of Health
Torrington Area Health District
350 Main Street
Torrington, CT 06790

Re: Well Permit Exception Application for 226 Millerton Rd., Lakeville, CT
DWS Project Number: #2025-0035

Dear Mr. Rubbo,

Section 19-13-B51m(b)(1) of the Regulations of Connecticut State Agencies (RCSA) prohibits the issuance of a well permit when a community water system is deemed available within 200 feet of the property line, unless it can be demonstrated that the conditions outlined in Section 19-13-B51m(c) that specify when a well permit exception may be granted exist.

RCSA Section 19-13-B51m(c) states:

“(c) The commissioner of health services, or his or her designee, may grant an exception to subsection (b) above upon a finding that such exception will not adversely affect the purity and adequacy of the supply nor the service of the system or it is determined that:

- (1) The community water system which serves the premises is unable to provide such premises with a pure and adequate supply of water: or*
- (2) If construction problems warrant such action.”*

Pursuant to Section 19-13-B51m(c) of the RCSA, this department has determined that installation of (1) individual drilled water supply well for the accessory structure on the property located at 226 Millerton Rd, Lakeville, Connecticut is allowable due to the construction problems associated with the required length of water supply line needed to serve the structure in addition to the need to cross wetlands.

Exception is granted to issue, if appropriate, a water supply well permit to develop one (1) drilled well.

This Well Permit Exception expires on **May 28, 2026**. If you require further information on this determination, please contact Mira Picchioni directly at mira.picchioni@ct.gov or (860) 973-1149.




Phone: (860) 509-7333
Telecommunications Relay Service 7-1-1
410 Capitol Avenue, P.O. Box 340308, MS#12DWS Hartford,
Connecticut 06134-0308 www.ct.gov/dph/publicdrinkingwater
Affirmative Action/Equal Opportunity Employer



Mr. Robert Rubbo
226 Millerton Rd, Lakeville, CT
May 28, 2025

Page 2

Sincerely,

A handwritten signature in black ink, appearing to read "Kerry A. Colson". The signature is fluid and cursive, with the first name "Kerry" being more prominent.

Kerry A. Colson, Esq
Acting Branch Chief

cc: Ingrid M. Jacobs, PE., Manager- Water Resources & Infrastructure Planning, AWC
George Johannesen-Allied Engineering Assoc. Inc.,
Justin Rompre, BS, RS, Sanitarian- Torrington Area Health District